Energy Northwest Forum


Snohomish County PUD Jason Zyskowski, PE 10/24/14





Snohomish County PUD Company Profile

- Total Electrical Customer: 327,000
- Energy Sales: 8,520,941 MWh
- Generating Capacity: 120 MW
- **Residential Rates:** 9.4¢ per kWh
- # of Substations: 86
- # of Circuits: 396
- **Resource Mix:** 8% Renewables
- Average # of Employees: 978








- Allows the generated power to be stored until it is needed by the end customer.
- Various Types
 - o Large Batteries, Flywheels, Compressed Air, Pumped Hydro
 - Connected directly to the Electrical System






Why is Energy Storage needed?



Challenge: Meet load growth and renewable portfolio standard requirements without the use of fossil fuels








Modular Energy Storage Architecture (MESA)

- Current grid energy storage offerings
 - Expensive (\$100k for 25 kw-hr system) →
 - Lack modularity
 - Lack interoperability
 - Lack scalability
 - Lack standardization
 - Monolithic; vendors operate beyond core expertise
- Large gap between battery manufacturers and utilities
 - Core suppliers cannot easily serve core customers

For \$30k you can get 24kw-hr of Li-ion storage with a Nissan Leaf wrapped around it...







Modular Energy Storage Architecture



MESA Standards Alliance

Open Standards for Energy Storage
Founding Members and Strategic Partners







Powering forward. Together.




















Projects partially funded through Washington State - Clean Energy Fund







MESA 1

- 2MW/1MWH Lithium Ion System
- Schedule
 - Design: through 1Q 2014
 - o Implementation: 2Q 2014 through 4Q 2014
- Partners





District Led Team Effort

- Substation Engineering / Construction
- Communications, SCADA, and IT
- System Planning and Protection
- Environmental and Safety
- Power Scheduling
- Facilities
- Cyber Security




























Asyrs2-502015A5 (192168-242) = TeamViewer - Free licence (nonico DC Bus Volts 800 VDC DC Bus Current -585 A Prev Banks	Reset Faults	Safety Relay OK
Bank	m ● 799 V -50.7 A	3.4 % 3.371 V 3.285 V
	● 798 V -50.4 A	
	🔵 798 V -50.7 A	
3 Enable Disable Close Open C	● 799 V -50.7 A	
5 Enable Disable Close Open	● 798 V -50.9 A	
6 Enable Disable Close Open e	● 798 V -50.4 A	A ATAL A OFF
7 Enable Disable 🔵 Close Open 🔵 🧶	 799 ∨ -50.7 A 799 ∨ -50.8 A 	
8 Enable Disable Close Open	● 799 V -50.8 A	
9 Enable Disable Close Open 6 10 Enable Disable Close Open 6	● 799 V -51.3 A -609.8 Å	3.4 % 3.363 V 3.280 V
ALL Enable Disable Open	Disco	onnect Local Rem















